

Redefining the Engineering Design Process



Speakers for Today's Adventure



Cathy Hall, LC, EDAC

Senior Lighting Designer
HGA Architects and Engineers
CHall@hga.com

Jeff Harris, PE

Director of Engineering
HGA Architects and Engineers
JWHarris@hga.com



Jill Imig, PE, EDAC

Senior Plumbing Engineer
Mechanical Department Leader
HGA Architects and Engineers
JImig@hga.com

Matthew Mikolainis, PE

Senior Project Manager
HGA Architects and Engineers
MMikolainis@hga.com



Learning Objectives

- Describe successful methods for evaluating and recommending engineering systems
- Understand how an A3 communicates options, analysis, and recommendations
- Recognize the value of continuous budget verification incorporated in component team design process
- Take away "lessons learned" from recent healthcare projects




Trends in Healthcare Engineering Design


- Compressed schedules
- Greater requirements for MEP Systems
- Cost constraints
- Supply chain issues
- Pandemic proofing



Design Process & Tools



Component Teams



Leader:
Civil Engineer

Team:
Owner's Representative
Project Designer
Project Architects
Mech. Engineer
Elec. Engineer
Construction Mgr.

Leader:
Proj. Designer

Team:
Owner's Representative
Project Architect
Architects
Mech. Engineer
Structural Engineer
Construction Mgr.

Leader:
Proj. Designer

Team:
Owner's Representative
Project Architect
Architects
Medical Planners
Interior Designers
Mech. Engineer
Electrical Engineer
Construction Mgr.

Leader:
Sr. Engineer

Team:
Owner's Representative
Mech. Engineer
Electrical Engineer
Project Architect
Structural Engineer
Srvcs. Technical Grp.
Construction Mgr.

Leader:
Sr. Engineer


Team:
Owner's Representative
Electrical Engineer
Mech. Engineer
Project Architect
Project Designer
Interior Designer
Srvcs. Technical Grp.
Construction Mgr.

Leader:
Sr. Engineer

Team:
Owner's Representative
Electrical Engineer
Mech. Engineer
Project Architect
Project Designer
Interior Designer
Srvcs. Technical Grp.
Construction Mgr.




Target Value Design




Box Whisker - MOB

October 3, 2019




FOUNDATIONS

| | Allow Budget | Trending | Delta | Impact |
|---------------|--------------|----------|-------|-----------------|
| Foundation SF | 131,988 | 131,988 | 0 | \$33,428 |
| Perimeter LF | 2,733 | 2,733 | 0 | - |
| Concrete CY | 7,077 | 7,456 | (379) | (\$42,958) |
| Pad/Mats (cy) | 2,291 | 2,838 | (547) | (\$180,126) |
| Strips (cy) | 866 | 1,055 | (189) | (\$74,228) |
| Walls (sf) | 32,931 | 27,594 | 5,337 | \$283,754 |
| Slabs (sf) | 143,466 | 143,056 | 411 | \$4,801 |
| Total: | | | | \$44,671 |



STRUCTURE

| | Allow Budget | Trending | Delta | Impact |
|----------------------|--------------|----------|-------|------------------|
| Structure SF | 327,318 | 327,318 | 0 | \$0 |
| Steel Tonnage (tons) | 2,479 | 2,358 | 120 | \$307,878 |
| Floor Deck (sq) | 3,232 | 3,175 | 57 | \$10,085 |
| Roof Deck (sq) | 41 | 44 | (4) | (\$539) |
| Concrete CY | 6,485 | 6,296 | 189 | \$51,858 |
| Total: | | | | \$369,262 |



ENCLOSURE

| | Allow Budget | Trending | Delta | Impact |
|--------------------------|--------------|----------|---------|------------------|
| Enclosure SF | 137,285 | 131,153 | 6,132 | \$31,991 |
| Precast/Stone/Brick (sf) | 54,530 | 58,625 | (4,095) | \$85,038 |
| Metal Panels (sf) | 23,803 | 9,178 | 14,625 | \$892,112 |
| Screenwall (sf) | 10,040 | 6,464 | 3,576 | \$106,048 |
| Curtainwall (sf) | 41,898 | 50,579 | (8,681) | (\$1,039,566) |
| Misc. (sf) | 7,014 | 6,307 | 707 | \$49,311 |
| Doors (ea) | 31 | 21 | 10 | \$81,650 |
| Total: | | | | \$206,583 |



Quote # C0-1830 - THEDACARE ORTHOPEDIC HOSPITAL Date: 12/15/2020

Page 2

| Qty | Type | Mfg | Description | Unit Price | Extd.Price |
|-----|------|------|----------------------|------------|--------------|
| 8 | DS4 | INTS | GD4DR-L7-35-D101-FL | \$206.00 | \$1,648.00 |
| 8 | DS4 | INTS | IRD402HZ-SF-SL | \$37.00 | \$296.00 |
| 8 | DS4 | INTS | I400 | \$5.50 | \$44.00 |
| 4 | DS5 | INTS | GD4DR-L3-35-D101-FL | \$196.00 | \$784.00 |
| 4 | DS5 | INTS | IRD402HZ-SF-SL | \$37.00 | \$148.00 |
| 4 | DS5 | INTS | I400 | \$5.50 | \$22.00 |
| 599 | DU11 | INTS | GD4DR-I 2-35-D101-WF | \$196.00 | \$117,404.00 |

| | | | | | | | |
|----|-------|-----|-------------------------------|----------|---------------------------------------|-----|-------|
| 26 | DS5 | 4 | 4" LED DOWNLIGHT - WOOD | TECH | E4R-F-LO-835-40-D-010-277-E4S-F25-BOX | 320 | 1280 |
| 27 | DU1 | 605 | 4" LED DOWNLIGHT | GOTHAM | EVO4-35/10-AR-WD-LSS-MVOLT-GZ10 | 122 | 73810 |
| 28 | DU1-W | 8 | 4" LED DOWNLIGHT - WET LISTED | GOTHAM | EVO4-35/10-AR-WD-LSS-MVOLT-GZ10 | 122 | 976 |
| 29 | DU2 | 196 | 4" LED DOWNLIGHT | GOTHAM | EVO4-35/15-AR-MWD-LSS-MVOLT-GZ10 | 122 | 23912 |
| 30 | DU2-W | 49 | 4" LED DOWNLIGHT - WET LISTED | GOTHAM | EVO4-35/15-AR-MWD-LSS-MVOLT-GZ10 | 122 | 5978 |
| 31 | DU4 | 170 | 4" LED SQUARE DOWNLIGHT | GOTHAM | EVO4SQ 35/20 AR LSS MVOLT GZ10 | 122 | 20740 |
| 32 | DU5 | 9 | 6" LED DOWNLIGHT - MRI | NEW STAR | DLM6-MR- HA-L4-A/A-3-UN-DM | 402 | 3618 |
| 33 | DU7 | 1 | 4" LED DOWNLIGHT | GOTHAM | EVO4-35/25-AR-MWD-LSS-MVOLT-GZ10 | 122 | 122 |
| 34 | DU8 | 21 | 4" LED SQUARE DOWNLIGHT | GOTHAM | EVO4SQ 35/10 AR LSS MVOLT GZ10 | 122 | 2562 |

| Distributor | | CTA | | WML | | MLS | | SPEC | | HGA | | chosen | Total |
|-----------------|-------------|---------------|---------------|-----------------|---------------|-----------------|--------------|-----------------|---------------|-----------------|--------------|---------------|-----------------|
| DESCRIPTION | TOTALS Qty. | \$ Quote \$ | Total | \$ Quote \$ | Total | \$ Quote \$ | Total | | Total | \$ Quote \$ | Total | BUY | \$ |
| | | \$ 603,194.85 | | \$ 2,100,810.73 | | \$ 1,462,203.96 | | \$ 1,956,960.67 | | \$ 1,718,558.00 | | | \$ 1,524,042.67 |
| | | \$ - | | \$ - | | \$ - | | \$ - | | \$ - | | | \$ - |
| | | \$ - | | \$ - | | \$ - | | \$ - | | \$ - | | | \$ - |
| | | \$ - | | \$ - | | \$ - | | \$ - | | \$ - | | | \$ - |
| | | \$ - | | \$ - | | \$ - | | \$ - | | \$ - | | | \$ - |
| | | \$ - | | \$ - | | \$ - | | \$ - | | \$ - | | | \$ - |
| | | \$ - | | \$ - | | \$ - | | \$ - | | \$ - | | | \$ - |
| | | \$ - | | \$ - | | \$ - | | \$ - | | \$ - | | | \$ - |
| LL3 | 226 | \$ - | 1004.21 | \$ 226,951.46 | 678.95 | \$ 153,442.70 | 1004.21 | \$ 226,951.46 | 750.00 | \$ 169,500.00 | 678.95 | \$ 153,442.70 | |
| LL3E | 44 | \$ - | 1220.00 | \$ 53,680.00 | 878.95 | \$ 38,673.80 | 1220.00 | \$ 53,680.00 | 800.00 | \$ 35,200.00 | 878.95 | \$ 38,673.80 | |
| LL4 | 52 | \$ - | 924.21 | \$ 48,058.92 | 652.63 | \$ 33,936.76 | 924.21 | \$ 48,058.92 | 400.00 | \$ 20,800.00 | 200.00 | \$ 10,400.00 | |
| LL5 | 4 | \$ - | 550.53 | \$ 2,202.12 | 631.58 | \$ 2,526.32 | 550.53 | \$ 2,202.12 | 150.00 | \$ 600.00 | 550.53 | \$ 2,202.12 | |
| LL7 | 7 | \$ - | 523.16 | \$ 3,662.12 | 605.26 | \$ 4,236.82 | 523.16 | \$ 3,662.12 | 400.00 | \$ 2,800.00 | 523.16 | \$ 3,662.12 | |
| LL8 | 5 | \$ - | 2281.05 | \$ 11,405.25 | 1473.68 | \$ 7,368.40 | 1473.68 | \$ 7,368.40 | | \$ - | 1473.68 | \$ 7,368.40 | |
| ML1 | 97 | 130.53 | \$ 12,661.41 | 93.68 | \$ 9,086.96 | 143.13 | \$ 13,883.61 | 130.53 | \$ 12,661.41 | 140.00 | \$ 13,580.00 | 93.68 | \$ 9,086.96 |
| ML2 | 598 | 98.95 | \$ 59,172.10 | 88.42 | \$ 52,875.16 | 86.32 | \$ 51,619.36 | 98.95 | \$ 59,172.10 | 100.00 | \$ 59,800.00 | 86.32 | \$ 51,619.36 |
| ML3 | 6 | 125.26 | \$ 751.56 | 104.21 | \$ 625.26 | 109.45 | \$ 656.70 | 125.26 | \$ 751.56 | 140.00 | \$ 840.00 | 104.21 | \$ 625.26 |
| ML4 | 56 | 141.05 | \$ 7,898.80 | 125.26 | \$ 7,014.56 | 119.99 | \$ 6,719.44 | 141.05 | \$ 7,898.80 | 140.00 | \$ 7,840.00 | 119.99 | \$ 6,719.44 |
| ML5 | 28 | 162.11 | \$ 4,539.08 | 167.37 | \$ 4,686.36 | 143.13 | \$ 4,007.64 | 162.11 | \$ 4,539.08 | 140.00 | \$ 3,920.00 | 143.13 | \$ 4,007.64 |
| ML6 | 72 | 104.21 | \$ 7,503.12 | 93.68 | \$ 6,744.96 | 86.32 | \$ 6,215.04 | 104.21 | \$ 7,503.12 | 100.00 | \$ 7,200.00 | 86.32 | \$ 6,215.04 |
| ML7 | 111 | 368.42 | \$ 40,894.62 | 88.42 | \$ 9,814.62 | 131.55 | \$ 14,602.05 | 368.42 | \$ 40,894.62 | | \$ - | 368.42 | \$ 40,894.62 |
| NL2 | 16 | \$ - | 89.47 | \$ 1,431.52 | 104.21 | \$ 1,667.36 | 89.47 | \$ 1,431.52 | 300.00 | \$ 4,800.00 | 89.47 | \$ 1,431.52 | |
| RL1 | 157 | 715.79 | \$ 112,379.03 | 747.37 | \$ 117,337.09 | 286.32 | \$ 44,952.24 | 715.79 | \$ 112,379.03 | 600.00 | \$ 94,200.00 | 286.32 | \$ 44,952.24 |
| RL3 | 29 | \$ - | 962.11 | \$ 27,901.19 | 605.26 | \$ 17,552.54 | 962.11 | \$ 27,901.19 | 600.00 | \$ 17,400.00 | 962.00 | \$ 27,898.00 | |
| RL4 | 42 | \$ - | 610.53 | \$ 25,642.26 | 410.53 | \$ 17,242.26 | 610.53 | \$ 25,642.26 | 600.00 | \$ 25,200.00 | 610.00 | \$ 25,620.00 | |
| T1 | 8 | 1531.56 | \$ 12,252.48 | 414.59 | \$ 3,316.72 | | \$ - | 1531.56 | \$ 12,252.48 | 2100.00 | \$ 16,800.00 | 414.59 | \$ 3,316.72 |
| UL1 | 103 | \$ - | 76.63 | \$ 7,892.89 | 126.32 | \$ 13,010.96 | 76.63 | \$ 7,892.89 | 100.00 | \$ 10,300.00 | 76.63 | \$ 7,892.89 | |
| UL2 | 3 | \$ - | 231.58 | \$ 694.74 | 178.95 | \$ 536.85 | 231.58 | \$ 694.74 | 186.00 | \$ 558.00 | 178.95 | \$ 536.85 | |
| UL3 | 10 | \$ - | 64.21 | \$ 642.10 | 105.26 | \$ 1,052.60 | 64.21 | \$ 642.10 | 100.00 | \$ 1,000.00 | 64.21 | \$ 642.10 | |
| WL1 | 13 | \$ - | 354.74 | \$ 4,611.62 | 426.32 | \$ 5,542.16 | 426.32 | \$ 5,542.16 | 400.00 | \$ 5,200.00 | 354.74 | \$ 4,611.62 | |
| YL1 | 50 | 456.72 | \$ 22,836.00 | 480.16 | \$ 24,008.00 | 315.79 | \$ 15,789.50 | 456.72 | \$ 22,836.00 | | \$ - | 315.79 | \$ 15,789.50 |
| YM1 | 17 | 309.94 | \$ 5,268.98 | 1014.74 | \$ 17,250.58 | 457.89 | \$ 7,784.13 | 309.94 | \$ 5,268.98 | | \$ - | 309.94 | \$ 5,268.98 |
| | | \$ - | | \$ - | | \$ - | | \$ - | | \$ - | | \$ - | |
| CL6 1651' total | 1 | \$ - | 38237.16 | \$ 38,237.16 | 65901.04 | \$ 65,901.04 | 38237.16 | \$ 38,237.16 | 126000.00 | \$ 126,000.00 | 38237.16 | \$ 38,237.16 | |
| CL7 130' total | 1 | \$ - | 3010.80 | \$ 3,010.80 | 5189.06 | \$ 5,189.06 | 3010.80 | \$ 3,010.80 | | \$ - | 3010.80 | \$ 3,010.80 | |

Tools | Owner's Project Requirements (OPR)



Tools | Owner's Project Requirements (OPR)

Introduction Section

STANDARDS

| Published Facility Standard | YES | NO | Date |
|---|-------------------------------------|-------------------------------------|------|
| Sustainable Standards | <input type="checkbox"/> | <input checked="" type="checkbox"/> | |
| Energy Conservation Standards | <input type="checkbox"/> | <input checked="" type="checkbox"/> | |
| Emergency Management Plan | <input type="checkbox"/> | <input checked="" type="checkbox"/> | |
| Facility Design Standards <i>(to be provided)</i> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | |
| Technology/AV Standards <i>(and security)</i> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | |
| Control Standards | <input type="checkbox"/> | <input checked="" type="checkbox"/> | |
| Finish Standard <i>(to be provided)</i> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | |

| Published Industry Standards | YES | NO | Edition |
|--|-------------------------------------|--------------------------|------------------|
| International Building Code (IBC) | <input checked="" type="checkbox"/> | <input type="checkbox"/> | 2015 |
| International Mechanical Code (IMC) <i>and WI SPS chapters</i> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | 2015 |
| International Fuel Gas Code (IFGC) <i>and WI SPS chapters</i> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | 2015 |
| NFPA 70 - National Electric Code (NEC) | <input checked="" type="checkbox"/> | <input type="checkbox"/> | 2017 |
| Plumbing Code (WI SPS chapters 352 through 387) | <input checked="" type="checkbox"/> | <input type="checkbox"/> | latest |
| Illumination Engineering Society Handbook | <input checked="" type="checkbox"/> | <input type="checkbox"/> | 10 th |
| ADA Standards for Accessible Design | <input checked="" type="checkbox"/> | <input type="checkbox"/> | 2010 |

| Renewable Power Sources | Further Discussion | YES | NO |
|------------------------------|-------------------------------------|--------------------------|-------------------------------------|
| Green Power Purchase Options | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| Solar Photovoltaics | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| Wind Turbines | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> |

SCOPE DELINEATION

| Systems | Owner Delegated | HGA Design Provided | Notes |
|-----------------------------|--------------------------|-------------------------------------|-------|
| Back-up fuel system | <input type="checkbox"/> | <input checked="" type="checkbox"/> | |
| A/V | <input type="checkbox"/> | <input checked="" type="checkbox"/> | |
| Security | <input type="checkbox"/> | <input checked="" type="checkbox"/> | |
| Access Control | <input type="checkbox"/> | <input checked="" type="checkbox"/> | |
| Low Voltage Systems Cabling | <input type="checkbox"/> | <input checked="" type="checkbox"/> | |
| Low Voltage Equipment | <input type="checkbox"/> | <input checked="" type="checkbox"/> | |
| CTV | <input type="checkbox"/> | <input checked="" type="checkbox"/> | |
| Irrigation System | <input type="checkbox"/> | <input checked="" type="checkbox"/> | |
| Chemical Systems | <input type="checkbox"/> | <input checked="" type="checkbox"/> | |



Tools | Owner's Project Requirements (OPR)

Mechanical Section

OUTDOOR DESIGN CONDITIONS

| Location | Cooling Season Conditions (WB/DB) | Heating Season Condition (DB) |
|--|-----------------------------------|-------------------------------|
| Green Bay, WI (2017 ASHRAE Handbook - Fundamentals) WMO 726450 (Austin Straubel Intl) | 88°F DB and 73.7°F WB | -7.9°F DB |
| WI Comm SPS 363 Table 363.0302 (Brown County, WI) | 87°F DB and 75°F WB | -15°F DB |

PRESSURE RELATIONSHIPS/MONITORING/CONTROL

Listed relationship based from FGI 2014, this table is used to validate the device capability used for local or BAS monitoring or control. Check boxes represent what will be provided in the design.

| Room Type or Description | Relationship (Inches WC) | Pressure (POS/NEG) | Local Monitor | BAS Monitor | BAS Control ONLY |
|------------------------------|--------------------------|--------------------|-------------------------------------|-------------------------------------|--------------------------|
| Operating Room/Delivery room | 0.01" | POS | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| Class "A" Procedure Room | 0.01" | POS | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| Endoscopy | 0.01" | POS | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| Trauma Room | 0.01" | POS | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| Catheterization | 0.01" | POS | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| Endoscopy | NR | POS | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| Endoscopy Equipment Cleaning | NR | NEG | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| ED/Radiology Waiting | NR | NEG | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| Pharmacy IV Mix | 0.02" | POS | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |

TEMPERATURE AND RELATIVE HUMIDITY REQUIREMENTS

Listed temperatures and relative humidity's based from FGI 2014, this table is used to validate the baseline and recognize user and facility expectations.

| Room Type or Description | Cooling Design Maximum | | Heating Design Minimum | |
|--|------------------------|-----------------------|------------------------|-----------------------|
| | Temp.°F | Relative Humidity %Rh | Temp.°F | Relative Humidity %Rh |
| Class "B", "C" Operating Suite | 60 | 55 | 75 | 20 30 |
| Procedure Rooms/Endoscopy/Bronchoscopy | 68 | 60 55 | 75 | 20 30 |
| Treatment/Intensive Care/Critical Care | 70 | 60 55 | 75 | 30 |
| Radiology | 72 | 60 55 | 78 | NA |
| All patient care areas not listed | 70 | 60 55 | 75 | NA |
| Laboratory | 70 | 50 | 75 | 30 |
| Pharmacy IV Mix/ANTE/HD | 68 | NA ? | 75 | NA ? |
| CSP Decontam | 60 | 60 55 | 65 | 30 |
| CSP Sterile Supply | 68 | 70 ? | 73 | NA |
| CSP Clean Workroom | 60 | 60 55 | 73 | 30 |
| Office Spaces or Staff Breakroom | 70 | 60 55 | 72 | 25 |

A3 to review 60/55 equipment options for the operating rooms

SYSTEM SPECIFICS

Listed items below are included unless check box is used

| Air Handling Unit Specifics | Further Review | NO |
|---|---------------------------------------|-------------------------------------|
| Direct Drive Supply/Return Fans with VFDs (no belts) | Y <input type="checkbox"/> | <input type="checkbox"/> |
| Array fans for Supply/Return (each fan independent VFD) | Y <input type="checkbox"/> | <input type="checkbox"/> |
| Electronic Com Motor (ECM) for Supply/Return fan Array | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| Redundancy on Supply Fans/Return Fans (N-1) | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| AHU sizing 120% of actual load required | Y <input type="checkbox"/> | <input type="checkbox"/> |
| Operating Room Cooling Redundancy | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> |
| Cooling Coil maximum velocity 500 FPM | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| Air Stream Disinfection (UV lights) | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| Air Stream Disinfection (Needlepoint Ionization) | <input checked="" type="checkbox"/> | <input type="checkbox"/> |



Tools | Owner's Project Requirements (OPR)

Electrical Section

| System | No Preference | Manufacturer |
|-----------------------------|----------------|--|
| Electrical Distribution | SQ.D preferred | Square D / Schneider Electrical, Eaton, GE |
| Emergency Standby Generator | | Cummins, Caterpillar, Kohler |
| Lighting | | Cooper, Acuity, Signify, Kenall, Axis |
| Lighting Control | | Watt Stopper, nLight, Crestron, Douglas |
| Lamps | | Sylvania, Osram |
| Wiring Devices | | Hubbell, Leviton, Pass & Seymour, Legrand |
| Fire Alarm | | Simplex, Notifier, Rauland |

| Incoming Service Redundancy | A3 | YES | NO |
|--|-------------------------------------|-------------------------------------|--------------------------|
| Single Utility Feed - A single service feed routed from utility owned substation | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| Redundant Utility Feed - Two service feeds from two separate utility owned substations - Research looped feed and redundant source feed - tbd, further review is necessary | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| <ul style="list-style-type: none"> Automatic Transfer - cost dependent on design - tbd, further review is necessary | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| <ul style="list-style-type: none"> Manual Transfer - if primary, automatic would be desired - tbd, further review is necessary | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| Load Shedding requirements only upon one generator failure. Transfer switches can be programmed to drop off in reverse order. | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |

| Branch of Power | N | LS | CR | EQ | UPS | Notes |
|----------------------------------|-------------------------------------|--------------------------|-------------------------------------|-------------------------------------|--------------------------|---|
| Telecommunication MDP | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | |
| Telecommunication Branch Closets | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | |
| Electrical spaces | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | |
| Mechanical spaces | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | |
| Imaging Equipment | | | | | | |
| 1. CT | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | Review with Staff for emergency power needs |
| 2. General Radiology | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | |
| 3. MRI | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | |
| 4. Ultrasound | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | |
| 5. Mobile Imaging Connection | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | |

| UPS Requirements | YES | NO | Notes |
|--|--------------------------|--------------------------|---|
| Individual equipment standalone UPS per equipment requirements | <input type="checkbox"/> | <input type="checkbox"/> | <p>MDF needs tbd?</p> <ul style="list-style-type: none"> Rack mounted UPS units for IDF's provided by IT Batteries not desired in OR 2x4's Review for a separate UPS just for the OR's Separate inverters for OR's (Review with staff including booms; review what was done at Marinette; Marinette has two sets of bug eyes per room in an |



Tools | Owner's Project Requirements (OPR)

Plumbing Section

Redundancy Requirements

What are the expectations of redundancy for the Plumbing Systems

| PLUMBING REDUNDANCY APPROACH | NONE | N+1 | Evaluate |
|----------------------------------|--------------------------|-------------------------------------|-------------------------------------|
| Domestic Water Booster Pump | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| Domestic Water Heating Equipment | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |

Booster Pump (if applicable)

| Detailed Description | YES | NO | Evaluate |
|-----------------------------|-------------------------------------|--------------------------|-------------------------------------|
| Pumps Sized for 50% of load | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| Pumps Sized for 33% of load | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| Pumps Sizing other | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| Variable Speed | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| Expansion Tank | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| Connect to BAS | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| Emergency Power | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> |

Domestic Water System

| Detailed Description | YES | NO | Evaluate |
|---|-------------------------------------|-------------------------------------|--------------------------|
| Copper | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| Pro-press Fittings | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| Soldered Only | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| Stainless Steel – first 40 feet at chlorine injection sites | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| Victaulic Fittings | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| Welded Only | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| PEX | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |

Oxygen System

| Detailed Description | YES | NO | Evaluate |
|--|-------------------------------------|-------------------------------------|--------------------------|
| Cylinder Manifold | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| Bulk on Site | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| Sized to accommodate all future phases – size for 1 and 2, space for phase 3 | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |

Medical Gas Alarm Systems

| Detailed Description | YES | NO | Evaluate |
|-------------------------------------|-------------------------------------|--------------------------|--------------------------|
| Area Alarm Panels Monitored on BAS | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| Master Alarm Panel Monitored on BAS | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |



Tools | Set Logs

| | | Evaluation Criteria | | | | | |
|-----------------|------------------------------------|---------------------|--------------|-------------|------------|--------------|-------------|
| | Description | Energy Cost | Capital Cost | Flexibility | Redundancy | Space Needed | Maintenance |
| Heating Systems | | | | | | | |
| Opt A | Steam Boilers with Heat Exchangers | 0 | 0 | 0 | 0 | 0 | + |
| Opt B | Gas Fired Condensing Water Boilers | + | 0 | + | + | + | 0 |
| Opt C | Electric Heating | -- | + | 0 | -- | + | -- |



Tools | A3

THOUGHT SIDE

A3. E1

TITLE:
EMERGENCY CAPACITY

TEAM: E&I
AUTHOR: KMB

1. Current State – The campus will require a new emergency distribution system due to the need for a new CUP.

2. Reason for Action – To determine what level of redundancy is desired/required for generator back up of the campus.

- Bullet 2.1 – Provide redundancy and resiliency to the electrical system.
- Bullet 2.2- To achieve the desired protocol during a power outage.
- Bullet 2.3 – Create an “automated” procedure during an outage.
- Bullet 2.4 – Provide N+1 redundancy to cover code required loads of a concurrent outage of the utility and a generator.
- Bullet 2.5 – Create an infrastructure capable of accommodating future needs/growth.

3. Target State – Appropriate Redundancy,

- Bullet 3.1; Patient Safety
- Bullet 3.2; Patient Safety and additional provisions
- Bullet 3.3; Patient safety, additional provisions and additional functional comforts.
- Bullet 3.4; No change in function or work process in the event of a power outage (being mindful that the secondary source is now the only source of power).

ACTION SIDE

4. Research Brainstorm Box – The availability of emergency power should be based upon reliability of the utility source, the desired resiliency of the system, the overall intent of the facility in the event of a natural disaster, and the configuration of the CUP.

- Bullet 4.1- How reliable is the utility? With the new Central Plant utilizing dual utility feeders how big is the concern of an outage.
- Bullet 4.2- What is the facility's role in the event of a catastrophic event in the area- Level 1 Trauma Center.
- Bullet 4.3- If a heat recovery option is selected for the CUP does this offset the first cost for additional generators?
- Bullet 4.4- Is a selective choice of redundancy more appropriate for a better ROI to insure both patient safety and maintaining standard operations?
- Bullet 4.5 – Can a modular infrastructure suit the needs of the desired option?

5. Implementation Plan – Options:

- Option 2.1; Code Required Minimum
 - Life Safety (egress, fire alarm, med gas)
 - Critical Branch (direct patient care)
 - Equipment Loads (building systems)
- Option 2.2; Standard of Care
 - Code Required Minimum
 - Additional Critical Branch Loads
 - Minimal additional EQ branch loads
- Option 2.3; Best Practice
 - Standard of Care
 - Additional Critical Branch Loads required for effective hospital operation
 - Select “Optional” Loads
 - All heating and cooling on Emergency power, Kitchen, BAS, “Full limited operation”
 - Loads necessary to keep critical functions operating in a disaster.
 - Select loads in new MOB which support Level 1 Trauma center functions.
- Option 2.4; Island Power
 - All loads

| OPTION | | | |
|--------|------------------|---|---|
| 21 | Code Minimum | Meets Code – (Worst Building you can legally build) | Building cannot continue to be occupied for extended duration. |
| 22 | Standard of Care | Meets Code and allows for minimal function of facility. | Building function and protocol would need to be revised during an outage. |
| 23 | Best Practices | Addresses patient care needs and select building functions. | Could occupy facility but some systems would not function. |
| 24 | Island Power | All building loads would function*. | Most expensive option |

• Additional Comments:

- Rammelkamp will need new generators by the time project is completed.
- CCP current has on site generators
- Consider sizing distribution and allowing physical space to add additional buildings and/or facility loads.

- On the March 9, 2022 meeting with UMPC, CJL, HGA, and the contracting team it was agreed upon to proceed with the basis of design, Option #1.

Process| Integration Events

IS A HOLISTIC APPROACH
ROOTED IN INTERDISCIPLINARY
EMPATHY



Process| Integration Events





Item

1. Introductions/ Attendance – 15 min
2. Bluebeam Session Overview – 15 min

- Teams are expected to populate the Revit model with all applicable elements in the spaces being integrated on prior to the PDF print of the Bluebeam session. There is no expectation to be fully coordinated with other trades, we will do this together as needed in the integration session.
- Bluebeam Sessions will be printed and sent out prior to the Integration Sessions.
- If you have comments or questions to be asked in the integration session, feel free to populate the notes in the Bluebeam session in the appropriate color as noted below prior to the meeting.
- Discipline color code filters:
 - **Red:** Electrical / Lighting / Technology/ Low Voltage
 - **Blue:** Plumbing
 - **Orange:** Medical Equipment
 - **Green:** Mechanical
 - **Magenta:** Planning/Design
- These filters will also be applied to the PDF prints from the Revit model to ease coordination efforts. The colors are applied as best as possible to the different disciplines; some Revit families prevent graphic overrides, but most items for coordination are colored accordingly.
- The team will be expected to have the Bluebeam session open during the integration meeting and following along in real time. Everyone will be responsible for their own markups in the appropriate color as the discussions occur. This helps to speed things along as well as accountability for the work to be done.

MetroHealth CCP Renovations
November 16, 2020
Page 2



Item

- As we go through each room on the agenda, we will review items in this order:
 - Notation Plans
 - Reflected Ceiling Plans
 - Elevations
 - With each drawing review, we will do our best to hit each discipline in this order:
 - Planning Intent Review
 - Design Intent Review
 - Discipline Reviews:
 - Lighting
 - Mechanical
 - Electrical
 - Low Voltage
 - Plumbing & Fire Protection
 - Medical Equipment
3. Spaces to be Reviewed – 3 hours
 - 4th Floor CCP Renovation Areas:
 - Typical Observation Room & Toilet
 - New Ante-Partum Room (Re-purpose discussion)
 - Nursery:
 - Typical CCN Nursery Bay
 - Wellbaby Nursery
 - Shared WB & CCN Support
 - Prep/ Recovery Room
 - Support Areas:
 - Nurse Stations (PIS, Patient Monitoring, Infant Security)
 - Lactation
 - Meds/ Nourish/ Clean
 - Staff Areas:
 - Locker Room/ Shower
 - Break Room
 4. Plus/Delta & Next steps – 15 min




Discipline color code filters:

- **Red:** Electrical / Lighting / Technology/ Low Voltage
- **Blue:** Plumbing
- **Orange:** Medical Equipment
- **Green:** Mechanical
- **Magenta:** Planning/Design








30 TRAUMA - SOUTH
1/4" = 1'-0"

31 TRAUMA - V
1/4" = 1'-0"



Process | BIM One Model



Design Team




Coming together to create a
“Single Source of Truth”



Design Assist Team



BIM One Model



INDUSTRY AVERAGE: 9.9 RFI's/million

RECENT COMPLETE PROJECT: 1.8 RFI's/million

Successful Projects:



**PROJECT DELIVERY
BEST PRACTICES**



**COLLABORATION-
ATTITUDE AND TOOLS**



**INNOVATION- PROCESS
AND PRODUCT**



Questions?

